



Mfg./Mkted. all types of Fire Extinguishers, Fire Hydrant & Alarm System, Spl. in Refilling & Maintenance Contractor

Corporate Office : 38A, Shrinagar Extension, Near Chandralok Square, Behind SNS Hospital, Khajrana Main Road, Indore - 452018 (MP)
Web.: www.firenetindia101.com

Email : support@firenetindia101.com, sales@firenetindia101.com
office.firenet@gmail.com

Ph. No.: 0731-4063151, Mob.: 88895-91888
Mobile No.: 88899-97672, 88893-03888



CERTIFICATE

This is to certify that we had carried out complete inspected internally and externally to Fire Extinguisher and certificate issue to :-


M/s St. Anthony High School

Address- Sonkatchh (M.P.)

Year of Contract	2024-2025	Date-26/12/2024
Certificate No.	FNT/IND/24-25/TSD/26636	
Warranty Period	From DECEMBER-2024 and Valid Up to DECEMBER-2025	
Warranty for	01-Year	
New/Refilled fire extinguisher	ABC- Type-Capacity-2 kgs.	2 Nos.
	ABC- Type-Capacity-4 kgs.	1 Nos.
	ABC- Type-Capacity-5 kgs.	2 Nos.
	ABC- Type-Capacity-6 kgs.	1 Nos.
	Total Quantity	6 Nos.
Inspection Details Of fire Extinguisher	<ol style="list-style-type: none"> 1. Check for proper sizes, types, quantity and placement of fire extinguishers. Ensure that each fire extinguisher is properly mounted, conspicuously located, not obstructed by objects and readily available for use in case of a fire. 2. Make sure the instruction label is legible and facing outward. 3. Check to be sure the extinguisher is fully pressurized, and/or at its full charged weight. Make sure the fire extinguisher hose is intact and free from obstruction. 4. Operate the pull pin or locking device and install a new tamper seal. Check for dents, corrosion or other signs of damage. 5. Look for any modifications to the fire extinguisher that could possibly reduce its functionality. 6. Verify that the extinguisher is current on all internal maintenance and pressure testing requirements. 7. Attach an updated tag or label as a record of proper maintenance. 	
Declaration	We further certify that (FIRE NET) has successfully checked above fire extinguisher which is in good & working condition but necessary periodical maintenance, services and refill when required to fire extinguisher will be done by us.	

Technical service Department

Signature of the Inspector



Our Branches : INDORE • BHOPAL • AHMEDABAD • PUNE • JAIPUR • MUMBAI